

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

**ESTE INFORME CONTIENE INFORMACION MUY IMPORTANTE SOBRE SU AGUA DE BEBER. TRADUZCALO O HABLE CON ALGUIEN QUE LO ENTIENDA BIEN.**

### **Monitoring Requirements Not Met for Aqua Pennsylvania, Inc., Bristol Division, PA1090001**

Our water system violated a monitoring requirement in 2019. Even though this was not an emergency, as our customer you have a right to know what happened and what we did to correct the situation.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. On June 25, 2019, we did not complete all of the monitoring for chlorine dioxide and chlorite and therefore, cannot be sure of the quality of our drinking water during that time.*

#### **What should I do?**

**There is nothing you need to do at this time.** You may drink the water. This is not an emergency. If it had been, you would have been notified immediately.

The table below lists the contaminants we did not properly test for, how often we are supposed to sample for chlorine dioxide and chlorite, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

<b>Contaminant</b>	<b>Required sampling frequency</b>	<b>Number of samples taken</b>	<b>When all samples should have been taken</b>	<b>When samples were taken</b>
Chlorine Dioxide and Chlorite	Daily	0	6/25/2019	6/26/2019

#### **What happened? What was done?**

The water treatment plant feeds chlorine dioxide for oxidation into the raw water entering the water treatment plant. As such, we are required to test for chlorine dioxide and chlorite (a disinfection byproduct) in the water leaving the plant on a daily basis. On June 25, 2019, this test was inadvertently missed. Operations were normal; but because the test was not done, we cannot be certain of the water quality as it pertains to chlorine dioxide and chlorite on that day. Required monitoring resumed on June 26, 2019 and the results were within our required limits.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

For more information, please contact:

<b>Responsible Person</b> Todd Duerr	<b>System Name</b> Aqua Pennsylvania Bristol	<b>Address (Street)</b> 762 West Lancaster Ave
<b>Phone Number</b> 877.987.2782	<b>System PWSID#</b> PA1090001	<b>Address (City, State, Zip)</b> Bryn Mawr, PA 19010

This notice is being sent to you by Aqua Pennsylvania, Inc.

PWS ID#: PA1090001

Date distributed: June 2020